

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YY083		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner ZONDLO, ED						Phone # (715)427-3345		1. Well Location				Fire # (if avail.)					
Mailing Address 640 MILL LN						Town of RIB LAKE						W2379					
City RIB LAKE						State WI		Zip Code 54470				Street Address or Road Name and Number					
County Taylor						Co. Permit #		Notification # 7143409701				Completed 04-12-2018					
Well Constructor (Business Name) RONALD A KOMAREK SR						Lic. # 610		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.3232 °N -90.1668 °W					
Address KOMAREK WELL DRILLING OGEMA WI 54459						Well Plan Approval #		NW		NW		Section 30					
								Township 33 N		Range 3 E							
Hicap Permanent Well #						Common Well #		Specific Capacity 0.8				2. Well Type Replacement					
Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ?				DIRTY WATER					
Private, potable						Hicap Property ? No		Construction Type Drilled				Method Code GPS008					
Heat Exchange ___ # of drillholes						Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		75						- - P -		HARDPAN		Surface		28	
						Rotary - Mud Circulation				- - C -		CLAY		28		46	
						Rotary - Air				- - G -		GRAVEL		46		51	
						Rotary - Air & Foam				- - C -		CLAY		51		73	
						Drill-Through Casing Hammer				- - Y -		SAND & GRAVEL		73		75	
						Reverse Rotary											
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		44 ft. below ground surface		16 in. above grade					
6.625		WHEATLAND 280 ASTM A53B 18.97# WELD JT				Surface		75		10. Pump Test		Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 52 ft. below surface		Disinfected ? Yes					
										Pumping at 6 GP M for 3 Hrs.		Capped ? Yes					
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method MOUNDED												Filled & Sealed Well(s) as needed? Yes					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
BENTONITE		Surface				2 S				13. Constructor / Supervisory Driller		Lic #					
										RK		04-25-2018					
										Drill Rig Operator		Lic or Reg #					
												Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		66

Comment:

Created On: 05-07-2018

Updated On: 06-10-2020

Review Status: