Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY255

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: EKMAN NICOTAZZO, MARLENE			Phone #
Mailing Address: PO BOX 97			
City: BAILEYS HARBOR	State: WI	Zip Code: 54202	
County: Door	Co. Permit #:	Notification #: 7116135601	Completed: 03-28-2018

Well Constructor (Business Name): MARK E EUCLIDE	Lic. #: 5905	Facility ID # (Public Wells):	
Address: EUCLIDE WELL DRILLING INC STURGEON BAY WI 54235		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of BAILEYS HARBOR

Fire # (if avail.): 7760

Street Address or Road Name and Number: 7760 FROG TOWN RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.0492 °N	-87.1272 °W			GPS008
SW NW or Govt Lot #	Section: 29	Township: 30 N	Range: 28 E	

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
4 IN WELL

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	145
6	145	222

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- - L -	LIMESTONE	Surface	222

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL P.E. WT. 18.97 ASTMA53B IPSCO (WELDED JOINT)	Surface	147
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 25 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	145	46 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
ME		04-02-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Collector Sewer - San or Storm		25

Comment:

Created On: 04-17-2018 Updated On: 12-03-2019 Review Status: