

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YY256		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner RASK, MICHAEL						Phone # (920)540-5785		1. Well Location				Fire # (if avail.)							
Mailing Address 759 WISCONSIN BAY RD								Town of LIBERTY GROVE				759							
City ELLISON BAY						State WI		Zip Code 54210				Street Address or Road Name and Number WISCONSIN BAY RD							
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #					
Door				7091778801		03-14-2018													
Well Constructor (Business Name) MARK E EUCLIDE				Lic. # 5905		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.2946 °N -87.012 °W				Method Code GPS008							
Address EUCLIDE WELL DRILLING INC STURGEON BAY WI 54235				Well Plan Approval #		SE SE		Section 31		Township 33 N		Range 29 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		2. Well Type New Well													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well #				constructed in							
						Hicap Property ? No		Reason for replaced or reconstructed well ?											
						Hicap Potable ? No													
						Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		15		No Rotary - Mud Circulation		No		- - C -		CLAY		Surface		15			
8		15		145		Yes Rotary - Air		Yes		- - L -		LIMESTONE		15		222			
6		145		222		No Rotary - Air & Foam		No											
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...		No											
						No Dual Rotary		No											
						Yes Temp. Outer Casing 8in. dia													
						Yes Removed? 15depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen														8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		100 ft. below ground surface				11. Well Is					
6		NEW BLACK STEEL P.E. WT. 18.97 ASTM A53B IPSCO (WELDED JOINT)				Surface		147		10. Pump Test				16 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 160 ft. below surface				Developed ? Yes					
										Pumping at 25 GP M for 2 Hrs.				Disinfected ? Yes					
										Pumping Method ?				Capped ? Yes					
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No					
Method BRADENHEAD														Filled & Sealed Well(s) as needed? No					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement													
CEMENT		Surface		145		29 S													
														13. Constructor / Supervisory Driller		Lic #		Date Signed	
														ME				03-21-2018	
														Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-17-2018

Updated On: 12-03-2019

Review Status: