Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY256

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RASK, MICHAEL	Phone #: (920)540-5785
Mailing Address: 759 WISCONSIN BAY RD	
City: ELLISON BAY	State: WI — Zip Code: 54210
County: Door	Co. Permit #:
Notification #: 7091778801	Completed: 03-14-2018
Well Constructor (Business Name): MARK E EUCLIDE	Lic. #: 5905
Facility ID # (Public Wells):	
Address: EUCLIDE WELL DRILLING INC STURGEON BAY WI 54235	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.4	

1. Well Location

Town of LIBERTY GROVE	Fire # (if avail.): 759
Street Address or Road Name and Number: WISCONSIN BAY RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.2946 °N -87.012 °W	Method Code: GPS008
SE SE or Govt Lot #	Section: 31 — Township: 33 N — Range: 29 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	15
8	15	145
6	145	222

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 15depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	15
-	-	L	-	LIMESTONE	15	222

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL P.E. WT. 18.97 ASTM A53B IPSCO (WELDED JOINT)	Surface	147
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

100 ft. below ground surface

10. Pump Test

Pumping level 160 ft. below surface

Pumping at 25 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	145	29 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
ME		03-21-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-17-2018 Updated On: 12-03-2019 Review Status: