

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YY259		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner HOLZEM, JOHN						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address 16610 BRIDGE CRK FLS CT								Town of GIBRALTAR				3821											
City SPRING						State TX		Zip Code 77379				Street Address or Road Name and Number 3821 GIBRALTAR RD											
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #									
Door				7090598501		03-19-2018																	
Well Constructor (Business Name) MARK E EUCLIDE				Lic. # 5905		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.1265 °N -87.2229 °W				Method Code GPS008									
Address EUCLIDE WELL DRILLING INC STURGEON BAY WI 54235				Well Plan Approval #				NW NE Section Township Range or Govt Lot # 33 31 N 27 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? 4IN													
				Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6																			
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?						Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
8		Surface		170		Rotary - Mud Circulation						- - L -		LIMESTONE		Surface		242					
6		170		242		<u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)																	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				16 in. above grade									
6		NEW BLACK STEEL P.E. WT. 18.97 ASTMA53B IPSCO (WELDED JOINT)				Surface		172		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 80 ft. below surface Pumping at 25 GP M for 2 Hrs. Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method BRADENHEAD														Filled & Sealed Well(s) as needed? Yes									
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement																	
CEMENT		Surface		170		70 S																	
														13. Constructor / Supervisory Driller				Lic #		Date Signed			
														ME						03-21-2018			
														Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Building Sanitary		10

Comment:

Created On: 04-17-2018

Updated On: 12-03-2019

Review Status: