Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY413

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FUST, MIKE			Phone #
Mailing Address: 970 CO E			
City: ADAMS	State: WI	Zip Code: 53910	
County: Adams	Co. Permit #:	Notification #: 7101238701	Completed: 03-18-2018
Well Constructor (Business Name): BRUCE A WALKER	Lic. #: 6143	Facility ID # (Public Wells):	
Address: WISCONSIN WELL & WATER SYSTEMS LLC, GRAND MARSH WI 53936		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.6	

1. Well Location

Town of ADAMS			Fire # (if avail.): 970
Street Address or Road Name and Number: CO E			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 43.8946 °N -89.7707 °W			Method Code: GPS008
SE SW or Govt Lot #:	Section: 34	Township: 17 N	Range: 6 E

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?
Construction Type: Jetted

3. Well serves # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ?
Hicap Property ?
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	57
1.25	57	60

Upper Enlarged Drillhole / Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	26
T	-	C	-	CLAY (BROWN)	26	46
-	-	C	S	SANDY CLAY	46	55
-	M	S	-	SAND (MED)	55	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2		Surface	57
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
1.25	SS CS WR #10 SLOT	57	60

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 26 ft. below surface
Pumping at 5 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
BW		04-18-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
HZ		04-18-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		52	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 05-07-2018 Updated On: 05-07-2018 Review Status: