Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY415

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: VALEZ, K			Phone #
Mailing Address: 1174 S GALE CT			
City: WISCONSIN DELLS	State: WI	Zip Code: 53965	
County: Adams	Co. Permit #:	Notification #: 7097654901	Completed: 03-07-2018

1. Well Location

Town of DELL PRAIRIE

Fire # (if avail.): 1174

Street Address or Road Name and Number: S GALE CT

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
BRUCE A WALKER	6143	

Latitude / Longitude in Decimal Degree (DD): 43.7235 °N -89.8115 °W

Method Code: SCR002

Well Plan Approval #:

SE	NW	Section	Township	Range
or Govt Lot #		5	14 N	6 E

Address: WISCONSIN WELL & WATER SYSTEMS LLC
GRAND MARSH WI 53936

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.4

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	53.5

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y Q S -	CAVING YELLOW SAND	Surface	15
T M S -	MED BROWN SAND	15	53.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	CRESLINE PVC 1120 SDR 20 ASTM F480	Surface	49.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	SS WW 12 SLOT	49.5	53.5

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 10 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
QUIK GROUT	Surface	46	4.5 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NEW

13. Constructor / Supervisory Driller	Lic #	Date Signed
BW		
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Septic or Holding, or POWTS Tank		66

Comment:

Created On: 04-17-2018 Updated On: 05-04-2020 Review Status: