

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YY416		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner PINGEL ENT					Phone #			1. Well Location				Fire # (if avail.)					
Mailing Address 2072 11TH AVE								Town of ADAMS				2072					
City ADAMS					State WI		Zip Code 53910		Street Address or Road Name and Number				11TH AVE				
County Adams		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #			
				7104372301		03-16-2018											
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code					
BRUCE A WALKER				6143				43.957 °N -89.7932 °W				SCR002					
Address WISCONSIN WELL & WATER SYSTEMS LLC GRAND MARSH WI 53936				Well Plan Approval #		NW SW		Section		Township		Range					
				Approval Date (mm-dd-yyyy)		or Govt Lot #		9		17 N		6 E					
Hicap Permanent Well #		Common Well #		Specific Capacity		0.8		2. Well Type New Well				of previous unique well # constructed in					
								Reason for replaced or reconstructed well ?				SAND IN WATER					
								Construction Type Drilled									
3. Well serves 1 # of INDUSTRY				Hicap Well ?		No											
Non-community				Hicap Property ?		No											
Heat Exchange ___ # of drillholes				Hicap Potable ?		No											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
9		Surface		93						- Q S -		CAVING SAND		Surface		15	
						Yes Rotary - Mud Circulation		No		T - S -		SAND (BROWN)		15		38	
						No Rotary - Air		No		R - C -		RED CLAY		38		45	
						No Rotary - Air & Foam		No		T - C -		BROWN CLAY		45		55	
						No Drill-Through Casing Hammer				- - C S		SANDY CLAY		55		62	
						No Reverse Rotary				- N S -		FINE SAND		62		84	
						No Cable-tool Bit ___ in. dia...		No		- M S -		MED SAND		84		93	
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		18 ft. below ground surface		14 in. above grade					
4		CRESLINE PVC 1120 SDR21 D2241				Surface		89									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes					
4		SS WW 15 SLOT				89		93		Pumping level 50 ft. below surface		Disinfected ? Yes					
										Pumping at 24 GP M for 3 Hrs.		Capped ? Yes					
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?		No			
Method PRESR TREM																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
QUICK GROUT				Surface		84		8 S		Filled & Sealed Well(s) as needed?		No					
												WANTS TO KEEP FOR BACK UP					
13. Constructor / Supervisory Driller												Lic #		Date Signed			
BW																	
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		125	Septic or Holding, or POWTS Tank		95

Comment:

Created On: 04-17-2018

Updated On: 02-21-2019

Review Status: