Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY416

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PINGEL ENT			Phone #
Mailing Address: 2072 11TH AVE			
City: ADAMS	State: WI	Zip Code: 53910	
County: Adams	Co. Permit #:	Notification #: 7104372301	Completed: 03-16-2018

Well Constructor (Business Name): BRUCE A WALKER	Lic. #: 6143	Facility ID # (Public Wells):	
Address: WISCONSIN WELL & WATER SYSTEMS LLC, GRAND MARSH WI 53936		Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.8	

3. Well serves 1 # of INDUSTRY
Non-community
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of ADAMS

Fire # (if avail.): 2072

Street Address or Road Name and Number: 11TH AVE

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 43.957 °N -89.7932 °W
Method Code: SCR002

NW SW or Govt Lot # | Section: 9 | Township: 17 N | Range: 6 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
SAND IN WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	93

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	Q	S	-	CAVING SAND	Surface	15
T	-	S	-	SAND (BROWN)	15	38
R	-	C	-	RED CLAY	38	45
T	-	C	-	BROWN CLAY	45	55
-	-	C	S	SANDY CLAY	55	62
-	N	S	-	FINE SAND	62	84
-	M	S	-	MED SAND	84	93

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	CRESLINE PVC 1120 SDR21 D2241	Surface	89
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	SS WW 15 SLOT	89	93

7. Grout or Other Sealing Material
Method PRESR TREM

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
QUICK GROUT	Surface	84	8 S

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 24 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No
WANTS TO KEEP FOR BACK UP

13. Constructor / Supervisory Driller	Lic #	Date Signed
BW		
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		125	Septic or Holding, or POWTS Tank		95

Comment:

Created On: 04-17-2018 Updated On: 02-21-2019 Review Status: