Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY686

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KUTZ, GENE	Phone #: (920)533-4250
Mailing Address: N3890 VISTA DR	
City: CAMPBELLSPORT	State: WI — Zip Code: 53010

County	Co. Permit #	Notification #	Completed
Fond du Lac		7125003104	04-05-2018

Well Constructor (Business Name): DANIEL J STEFFES	Lic #: 6109
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: BADGER WELL DRLG MT CALVARY WI 53057	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 3.1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of OSCEOLO

Fire # (if avail.): N3878

Street Address or Road Name and Number: VISTA DR

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.6801 °N	-88.2009 °W			GPS008

NE	SE	Section	Township	Range
or Govt Lot #		15	14 N	19 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	162

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	G	G	GRAVEL TO STONES	Surface	47
-	-	Y	-	GRAVEL TO SAND	47	65
-	-	Z	-	GRAVEL TO CLAY	65	122
-	-	C	S	SANDY CLAY	122	133
-	-	Z	-	GRAVEL & CLAY	133	153
-	-	L	-	LIMESTONE	153	162

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B EXL TUBE 6.625 X .280 EL20 PLAIN END	Surface	153
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		3 S

9. Static Water Level
62 ft. below ground surface

10. Pump Test
Pumping level 70 ft. below surface
Pumping at 25 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DS		04-05-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JH		04-05-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Sewer - Building Sanitary		45
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 05-07-2018 Updated On: 10-08-2019 Review Status: