

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YY691		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner WEIX, MIKE						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 6862 BEAVER DAM RD								Town of ADDISON				6811	
City ALLENTON						State WI		Zip Code 53002				Street Address or Road Name and Number BEAVER DAM RD	
County Washington		Co. Permit #		Notification # 7123440103		Completed 03-29-2018		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) DANIEL J STEFFES				Lic. # 6109		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.4508 °N -88.3772 °W				Method Code GPS008	
Address BADGER WELL DRLG MT CALVARY WI 53057				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 5 11 N 18 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) 6		From (ft.) Surface		To (ft.) 162		Upper Enlarged Drillhole Lower Open Bedrock		8. Geology		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)	
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Geology Codes - - Z - CLAY TO GRAVEL - - X - SAND TO CLAY - - L - LIMESTONE - - H - SHALE				Surface 110 110 129 129 145 145 162	
6. Casing, Liner, Screen													
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly ASTM A53B EXL TUBE 6.625 X .280 EL20 PLAIN END				From (ft.) Surface		To (ft.) 129		9. Static Water Level 40 ft. below ground surface		11. Well Is 18 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level 60 ft. below surface Pumping at 25 GP M for 1 Hrs. Pumping Method ?		Developed ? Yes Disinfected ? Yes Capped ? Yes	
7. Grout or Other Sealing Material Method MOUNDED													
Kind of Sealing Material GRANULAR BENTONITE		From (ft.) Surface		To (ft.)		# Sacks Cement 3 S		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?		Yes			
13. Constructor / Supervisory Driller													
DS		Lic #		Date Signed 03-29-2018									
Drill Rig Operator GM		Lic or Reg #		Date Signed 03-29-2018									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 05-07-2018

Updated On: 07-08-2019

Review Status: