Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY847

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ABTS, MITCH		Phone #: (507)450-6625
Mailing Address: S2578 BROWN RD		
City: COCHRANE	State: WI	Zip Code: 54622

County	Co. Permit #	Notification #	Completed
Buffalo		7087422101	02-16-2018

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
EDWARD A HARTERT	4424	

Address: HARTERT WELL DRILLING, WABASHA MN 55981

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		15

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of BELVIDERE

Fire # (if avail.): S2578

Street Address or Road Name and Number: S2578 BROWN RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.2192 °N	-91.8415 °W			GCD013

SW	SE	Section	Township	Range
or Govt Lot #		8	20 N	12 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	6
6	6	53

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....

Yes Temp. Outer Casing 10in. dia
Yes Removed? 6depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S	-	SAND, CAVING, BROWN & SOFT	Surface	53

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 19.45 LBS FOOT ASTM A53B IPSCO T-N-C	Surface	49
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	TELESCOPING S.S. 12 SLOT	49	53

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE AROUND CASING	Surface		

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 26 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
EH		03-10-2018
Drill Rig Operator	Lic or Reg #	Date Signed
EH		03-10-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		94	Sewer - Building Sanitary		64
Building Drain - Sanitary		51	Septic or Holding, or POWTS Tank		58

Comment: WAS NO OTHER WELLS ON PROPERTY

Created On: 03-27-2018 Updated On: 05-01-2020 Review Status: