

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YY848		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																																															
Property Owner THEURER, RICHARD						Phone #		1. Well Location				Fire # (if avail.)																																													
Mailing Address S2285 MARTIN LN						Town of BELVIDERE						W1737																																													
City COCHRANE						State WI		Zip Code 54622				Street Address or Road Name and Number W1737 INDIAN POINT LN																																													
County Buffalo		Co. Permit #		Notification # 7110704301		Completed 03-20-2018		Subdivision Name				Lot #		Block #																																											
Well Constructor (Business Name) EDWARD A HARTERT				Lic. # 4424		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.2662 °N -91.8804 °W				Method Code GCD013																																											
Address HARTERT WELL DRILLING WABASHA MN 55981				Well Plan Approval #		NW SE Section Township Range or Govt Lot # 30 21 N 12 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled																																																	
Hicap Permanent Well #				Common Well #		Specific Capacity 16																																																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																																																					
4. Potential Contamination Sources - ON REVERSE SIDE																																																									
5. Drillhole Dimensions and Construction Method														8. Geology																																											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)																																			
8		Surface		5		Rotary - Mud Circulation				Rotary - Air				Rotary - Air & Foam				Drill-Through Casing Hammer				Reverse Rotary				Cable-tool Bit ___ in. dia...				Dual Rotary				Temp. Outer Casing 8in. dia				T H Y - SAND & GRAVEL, BROWN, HARD				Surface				33											
4		5		45		Yes Removed? 5depth ft. (If NO explain on back side)				T S S - SAND, BROWN, SOFT				33				45																																							
6. Casing, Liner, Screen														9. Static Water Level														11. Well Is																													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.)		To (ft.)		13 ft. below ground surface														18 in. above grade																															
4		STEEL, 11.00 LBS FOOT ASTM A53B IPSCO T-N-C						Surface		41		10. Pump Test Pumping level 14 ft. below surface Pumping at 16 GP M for 1 Hrs. Pumping Method ?														Developed ? Yes Disinfected ? Yes Capped ? Yes																															
Dia. (in.)		Screen type, material & slot size						From (ft.)		To (ft.)		4 1 41 45																																													
4		TELESOPING, S.S. 12 SLOT						41		45		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No																																													
7. Grout or Other Sealing Material Method														13. Constructor / Supervisory Driller														Lic #														Date Signed															
Kind of Sealing Material						From (ft.)		To (ft.)		# Sacks Cement						EH														04-04-2018																											
GRANULAR BENTONITE AROUND CASING						Surface		41		45						Drill Rig Operator														Lic or Reg #														Date Signed													
4						41		45		EH														04-04-2018																																	

4a. Potential Contamination Sources

Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		72	Shoreline/Pool		105
Building Drain - Sanitary		25	Sewer - Building Sanitary		59
			Septic or Holding, or POWTS Tank		66

Comment: DIDN'T MEET HOMEOWNER. NEW HOUSE & NEW WELL.

Created On: 04-17-2018

Updated On: 05-01-2020

Review Status: