Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY848

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: THEURER, RICHARD			Phone #
Mailing Address: S2285 MARTIN LN			
City: COCHRANE	State: WI	Zip Code: 54622	
County: Buffalo	Co. Permit #:	Notification #: 7110704301	Completed: 03-20-2018

1. Well Location

Town of BELVIDERE

Fire # (if avail.): W1737

Street Address or Road Name and Number: W1737 INDIAN POINT LN

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
EDWARD A HARTERT	4424	

Latitude / Longitude in Decimal Degree (DD): 44.2662 °N -91.8804 °W

Method Code: GCD013

Well Plan Approval #:

NW SE or Govt Lot #	Section	Township	Range
	30	21 N	12 W

Address: HARTERT WELL DRILLING, WABASHA MN 55981

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		16

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	5
4	5	45

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing 8in. dia

Yes Removed? 5depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T H Y -	SAND & GRAVEL, BROWN, HARD	Surface	33
T S S -	SAND, BROWN, SOFT	33	45

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	STEEL, 11.00 LBS FOOT ASTM A53B IPSCO T-N-C	Surface	41
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	TELESCOPING, S.S. 12 SLOT	41	45

9. Static Water Level

13 ft. below ground surface

10. Pump Test

Pumping level 14 ft. below surface

Pumping at 16 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE AROUND CASING	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
EH		04-04-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
EH		04-04-2018

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		72
Building Drain - Sanitary		25
Shoreline/Pool		105
Sewer - Building Sanitary		59
Septic or Holding, or POWTS Tank		66

Comment: DIDN'T MEET HOMEOWNER. NEW HOUSE & NEW WELL.

Created On: 04-17-2018 Updated On: 05-01-2020 Review Status: