

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YY983		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner KLEINSMITH, TROY						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address W7950 OLD HWY 93						Town of HOLLAND						W7950			
City HOLMEN						State WI		Zip Code 54636				Street Address or Road Name and Number W7950 OLD HWY 93			
County La Crosse		Co. Permit # 10		Notification # 7089677101		Completed 02-28-2018		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) TIMOTHY M LYSAKER				Lic. # 6199		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.014 °N -91.3033 °W				Method Code GPS008	
Address TIM LYSAKER WELL DRLG & PUMP SERV LLC HOLMEN WI 54636				Well Plan Approval #				SE SW		Section 23		Township 18 N		Range 8 W	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.6				2. Well Type Replacement of previous unique well # TG611 constructed in 2005					
3. Well serves 1 # of Private, potable				Hicap Well ? No Hicap Property ? No				Reason for replaced or reconstructed well ? OLD WELL PUMPS SAND							
Heat Exchange ___ # of drillholes				Hicap Potable ?				Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 4		From (ft.) Surface		To (ft.) 125		Upper Enlarged Drillhole				Lower Open Bedrock					
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - Y -				SAND & GRAVEL				Surface		125					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
4		NEW-BLACK-P.E. STEEL .237 WALL 10.79 # ASTM A53B WHEATLAND WELDED				Surface		121							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
3.5		12 CONT SLOT PVC JOHNSON				121		125							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
BENTONITE CRUMBLES				Surface		121		1 S							
9. Static Water Level															
75 ft. below ground surface															
10. Pump Test															
Pumping level 95 ft. below surface															
Pumping at 12 GP M for 3 Hrs.															
Pumping Method ?															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
TL				02-28-2018											
Drill Rig Operator				Lic or Reg #				Date Signed							
DL				02-28-2018											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Sewer - Building Sanitary		29
Building Drain - Sanitary		29	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 04-17-2018

Updated On: 04-30-2020

Review Status: