Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY983

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	KLEINSMITH, TROY
Phone #	
Mailing Address	W7950 OLD HWY 93
City	HOLMEN
State	WI
Zip Code	54636

County	Co. Permit #	Notification #	Completed
La Crosse	10	7089677101	02-28-2018

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
TIMOTHY M LYSAKER	6199	

Address: TIM LYSAKER WELL DRLG & PUMP SERV LLC
HOLMEN WI 54636

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.6

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of HOLLAND

Fire # (if avail.): W7950

Street Address or Road Name and Number: W7950 OLD HWY 93

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.014 °N -91.3033 °W	GPS008

SE SW or Govt Lot #	Section	Township	Range
	23	18 N	8 W

2. Well Type Replacement
of previous unique well # TG611 constructed in 2005

Reason for replaced or reconstructed well ?
OLD WELL PUMPS SAND

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	125

Upper Enlarged Drillhole
Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	125

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW-BLACK-P.E. STEEL .237 WALL 10.79 # ASTM A53B WHEATLAND WELDED	Surface	121
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.5	12 CONT SLOT PVC JOHNSON	121	125

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CRUMBLES	Surface	121	1 S

9. Static Water Level
75 ft. below ground surface

10. Pump Test
Pumping level 95 ft. below surface
Pumping at 12 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TL		02-28-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DL		02-28-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80
Building Drain - Sanitary		29
Sewer - Building Sanitary		29
Septic or Holding, or POWTS Tank		70

Comment:

Created On: 04-17-2018 Updated On: 04-30-2020 Review Status: