Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY984

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	CLICTH, ADAM
Phone #	
Mailing Address	W6027 ANDERSON RD
City	HOLMEN
State	WI
Zip Code	54636

County	Co. Permit #	Notification #	Completed
La Crosse	65	7096965901	03-14-2018

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
TIMOTHY M LYSAKER	6199	

Address: TIM LYSAKER WELL DRLG & PUMP SERV LLC
HOLMEN WI 54636

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 0.1

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Fire # (if avail.): W6027

Town of ONALASKA

Street Address or Road Name and Number: W6027 ANDERSON RD

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 43.9821 °N -91.2066 °W

Method Code: GPS008

NW NW or Govt Lot #	Section	Township	Range
	3	17 N	7 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WATER SUPPLY

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	120

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	Q	S	M	SAND/SILT/MUD CAVING SOFT	Surface	80
T	Q	H	-	BROWN SHALE CAVING SOFT	80	86
G	M	H	-	GRAY SHALE NON CAVING MED-HARD	86	105
R	H	N	-	GRAY SAND ROCK NON CAVING MED-HARD	105	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND WELDED NEW P.E. BLACK STEEL ASTM A53B 18.97# .280 WALL	Surface	86
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method BENTONITE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CRUMBLES	Surface	86	3 S

9. Static Water Level
11 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
TL		03-14-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DL		03-14-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60
Building Drain - Sanitary		24

Type	Qualifier	Distance
Sewer - Building Sanitary		27
Ditch or Culvert		10
Septic or Holding, or POWTS Tank		45

Comment:

Created On: 05-07-2018 Updated On: 05-31-2018 Review Status: