Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YY987

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WING, DAN & KATHY			Phone #
Mailing Address: W7421 KIP ST			
City: HOLMEN	State: WI	Zip Code: 54636	
County: La Crosse	Co. Permit #: 19	Notification #: 7106914801	Completed: 03-20-2018

Well Constructor (Business Name): TIMOTHY M LYSAKER	Lic. #: 6199	Facility ID # (Public Wells)	
Address: TIM LYSAKER WELL DRLG & PUMP SERV LLC HOLMEN WI 54636		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.3	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.): W7421

Town of HOLLAND

Street Address or Road Name and Number: W7421 KIP ST

Subdivision Name: ASSESSORS PLAT #1	Lot #: 18	Block #

Latitude / Longitude in Decimal Degree (DD): 43.9686 °N -91.2767 °W			Method Code: GPS008
NW NE or Govt Lot #	Section: 12	Township: 17 N	Range: 8 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WATER SUPPLY

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	108

Upper Enlarged Drillhole
Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	108

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW P.E. BLACK STEEL ASTM A53B .237 WALL 10.97# WHEATLAND WELDED	Surface	104
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.5	JOHNSON 12 SLOT CONT STAINLESS STEEL	104	108

7. Grout or Other Sealing Material

Method BENTONITE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CRUMBLES	Surface	104	1 S

9. Static Water Level
55 ft. below ground surface

10. Pump Test
Pumping level 90 ft. below surface
Pumping at 10 GP M for 8 Hrs.
Pumping Method ?

11. Well Is
17 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TL		03-20-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DL		03-20-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		52
Building Drain - Sanitary		10
Sewer - Building Sanitary		15
Septic or Holding, or POWTS Tank		43

Comment:

Created On: 05-07-2018 Updated On: 04-30-2020 Review Status: