Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YZ033

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PIERCE, JOHN	Phone #
Mailing Address: 13419 14TH ST	
City: OSSEO	State: WI — Zip Code: 54758

County	Co. Permit #	Notification #	Completed
Eau Claire	34066	7088545101	02-28-2018

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
DONALD S FEDIE	127	

Address: FEDIE WELL DRILLING & PUMP SERVICE INC
MONDOVI WI 54755-7729

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.4

3. Well serves 1 # of CABIN
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of BRIDGE CREEK

Fire # (if avail.): S1155

Street Address or Road Name and Number: S11550 WARNER RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.6609 °N	-91.0653 °W			GPS008

SW	NE	Section	Township	Range
or Govt Lot #		11	25 N	6 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	4
6	4	55

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOP SOIL	Surface	1
T	N	S	-	FINE BROWN SAND	1	45
T	V	N	-	SOFT NON CAVING BROWN SANDSTONE	45	50
T	H	N	-	FIRM BROWN SANDSTONE	50	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	T/C PIPE ASTM A53 GR B 19.45 LBS FT WHEATLAND	Surface	50
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY/BENTONITE	Surface	4	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DF		03-10-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: NO SEPTIC/SEWER

Created On: 04-17-2018 Updated On: 08-01-2019 Review Status: