Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YZ035

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BOOS, GORDY	Phone #
Mailing Address: N1817 1000TH ST	
City: EAU CLAIRE	State: WI — Zip Code: 54701

County	Co. Permit #	Notification #	Completed
Dunn	2270	7088547901	03-21-2018

Well Constructor (Business Name): DONALD S FEDIE	Lic. #: 127
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: FEDIE WELL DRILLING & PUMP SERVICE INC MONDOVI WI 54755-7729	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity: 2	

3. Well serves 1 # of POLE SHED
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of ROCK CREEK	Fire # (if avail.): 1817
Street Address or Road Name and Number: 1000TH ST	
Subdivision Name	Lot # / Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.747 °N -91.6592 °W	GPS008

NW SE or Govt Lot #	Section	Township	Range
	12	26 N	11 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	6
6	6	100

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - S -	BROWN SAND	Surface	40
T - Y -	BROWN SAND & GRAVEL	40	60
G - Y -	GRAY SAND & GRAVEL	60	70
G - X -	GRAY CLAY & SAND	70	75
T Q N -	CAVING BROWN S.S.	75	78
T H N -	FIRM BROWN S.S.	78	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	T/C PIPE ASTM A53 GRB 19.45LBS FT WHEATLAND	Surface	79
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
60 ft. below ground surface

10. Pump Test
Pumping level 70 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY WITH BENTONITE	Surface	6	S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DF		03-25-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95	Sewer - Building Sanitary		25
Landfill		1380	Septic or Holding, or POWTS Tank		65

Comment:

Created On: 05-07-2018 Updated On: 05-07-2018 Review Status: