

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YZ042		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BORNTRAGER, FELTY						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address N13994 CTY RD G						Town of GARFIELD						N13994					
City OSSEO						State WI		Zip Code 54758				Street Address or Road Name and Number					
County Jackson						Co. Permit #		Notification # 7088546501		Completed 03-12-2018		Subdivision Name		Lot #		Block #	
Well Constructor (Business Name) DONALD S FEDIE						Lic. # 127		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.5784 °N -91.144 °W				Method Code GPS008			
Address FEDIE WELL DRILLING & PUMP SERVICE INC MONDOVI WI 54755-7729						Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW NW Section Township Range or Govt Lot # 8 24 N 6 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
Hicap Permanent Well #						Common Well #		Specific Capacity 1									
3. Well serves 1 # of POLE SHED Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				8. Geology						
10 Surface 30			No Rotary - Mud Circulation No				- - I - TOP SOIL				From (ft.) To (ft.) Surface 2						
6 30 150			No Rotary - Air No				T H N - FIRM BROWN S.S.				2 25						
			No Rotary - Air & Foam No				G H N C FIRM GRAY S.S. WITH CLAY				25 125						
			No Drill-Through Casing Hammer				G H N - FIRM GRAY S.S.				125 150						
			No Reverse Rotary														
			Yes Cable-tool Bit 10in. dia... Yes														
			No Dual Rotary No														
			No Temp. Outer Casing ___ in. dia														
			No Removed? ___ depth ft. (If NO explain on back side)														
6. Casing, Liner, Screen																	
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			11. Well Is			
6			T/C PIPE ASTM A53 GRB 19.45LBS FT WHEATLAND				Surface		36		70 ft. below ground surface			24 in. above grade			
Dia. (in.)			Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test			Developed ? Yes Disinfected ? Yes Capped ? Yes			
											Pumping level 85 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ?						
7. Grout or Other Sealing Material																	
Method TREMME PIPE PUMPED																	
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No								
NEAT GROUT CEMENT			Surface		30		16 S		Filled & Sealed Well(s) as needed? No								
13. Constructor / Supervisory Driller																	
DF			Lic #		Date Signed		03-20-2018										
Drill Rig Operator			Lic or Reg #		Date Signed												

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 05-07-2018

Updated On: 03-20-2019

Review Status: