Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YZ095

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: OAKS, DAN			Phone #
Mailing Address: 3516 10 PT LANE			
City: FRANKSVILLE	State: WI	Zip Code: 53126	
County: Racine	Co. Permit #:	Notification #: 7087810401	Completed: 03-08-2018

Well Constructor (Business Name): KENNETH J KRIZAN	Lic. #: 6519	Facility ID # (Public Wells):	
Address: KRIZAN WELL DRLG & PUMP UNION GROVE WI 53182-9659		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.5	

3. Well serves 1 # of BUSINESS
Non-community
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of RAYMOND

Fire # (if avail.)

Street Address or Road Name and Number
3516 10 PT LANE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
42.7801 °N	-87.9582 °W			GPS008
SE NE or Govt Lot #	Section: 25	Township: 4 N	Range: 21 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW CONST

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	225

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Yes Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	-	C	-	YELLOW CLAY	Surface	10
U	-	C	-	BLUE CLAY	10	30
U	-	C	G	STONEY BLUE CLAY	30	130
-	-	P	-	HARDPAN	130	140
-	-	L	-	LIMEROCKS	140	225

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND USA ASTM A53B E 6.625 X .280 EL FULL 20 WELDED	Surface	140
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
90 ft. below ground surface

10. Pump Test
Pumping level 110 ft. below surface
Pumping at 50 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 MESH BENTONITE	Surface	140	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE THERE

13. Constructor / Supervisory Driller	Lic #	Date Signed
KK		04-02-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-17-2018 Updated On: 04-17-2018 Review Status: