

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YZ096		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner ROLAND MACHINERY CO						Phone # (262)835-2710		1. Well Location				Fire # (if avail.)					
Mailing Address 3540 TEN POINT LN						Town of RAYMOND						3540					
City FRANKSVILLE						State WI		Zip Code 53126				Street Address or Road Name and Number TEN POINT LN					
County Racine		Co. Permit #		Notification # 7087810402		Completed 03-09-2018		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) KENNETH J KRIZAN				Lic. # 6519		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.7801 °N -87.9582 °W				Method Code GPS008					
Address KRIZAN WELL DRLG & PUMP UNION GROVE WI 53182-9659				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 25 4 N 21 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW CONST Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 2.5													
3. Well serves 1 # of BUSINESS Non-community Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		225		No Rotary - Mud Circulation No Rotary - Air No Rotary - Air & Foam Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No Dual Rotary No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Y - C - U - C - U - C G - - P - - - L -		YELLOW CLAY BLUE CLAY STONEY BLUE CLAY HARDPAN LIMEROCK		Surface 10 30 130 140 225			
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 90 ft. below ground surface				11. Well Is 20 in. above grade			
6		WHEATLAND USA ASTM A53BE 6.625 X .280 EL FULL 20 WELDED				Surface		140		10. Pump Test Pumping level 110 ft. below surface Pumping at 50 GP M for 3 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material Method MOUNDED												12. Notified Owner of need to fill & seal ? No					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? NONE THERE							
#8 MESH BENTONITE				Surface		140		S									
13. Constructor / Supervisory Driller												Lic #		Date Signed			
KK														04-03-2018			
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	03/09/2018	SAMPLES TO BE TAKEN AT LATER DATE.

Created On: 04-17-2018

Updated On: 03-13-2019

Review Status: