Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YZ099

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GANCARZ, STEPHEN			Phone #
Mailing Address: 5034 NANSCHE RD			
City: MT PLEASANT	State: WI	Zip Code: 53403	
County: Racine	Co. Permit #:	Notification #: 7074558001	Completed: 01-15-2018

Well Constructor (Business Name): KENNETH J KRIZAN	Lic. #: 6519	Facility ID # (Public Wells):	
Address: KRIZAN WELL DRLG & PUMP UNION GROVE WI 53182-9659		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity:	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Village of MT PLEASANT

Fire # (if avail.)

Street Address or Road Name and Number
5034 NANSCHE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
42.6722 °N	-87.8084 °W			GCD013

NE SW or Govt Lot #	Section	Township	Range
	32	3 N	23 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WELL NOT TO CODE

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	145

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	-	C	-	YELLOW CLAY	Surface	10
U	-	C	-	BLUE CLAY	10	30
U	-	C	G	STONEY BLUE CLAY	30	80
-	-	P	-	HARD PAN	80	97
-	-	L	-	LIME ROCK	97	145

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND USA ASTM A53BE 6.625 X .280 EL FULL 20 WELDED	Surface	97
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 10 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 MESH BENTONITE	Surface	97	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KK		01-30-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 02-19-2018 Updated On: 06-27-2019 Review Status: