

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YZ311		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner DVORAK, DAN						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 628 N 4TH						Town of RIB FALLS						1480			
City EDGAR						State WI		Zip Code 54426				Street Address or Road Name and Number			
County Marathon						Co. Permit #		Notification # 7106614301				Completed 03-23-2018			
Well Constructor (Business Name) JAMES HORNUNG JR						Lic. # 9013		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.95731 °N -89.90022 °W			
Address HORNUNG WELL DRLG LLC MERRILL WI 54452						Well Plan Approval #		NW NW		Section 34		Township 29 N			
Hicap Permanent Well #						Common Well #		Specific Capacity				Range 5 E			
3. Well serves 1 # of Private, potable						Hicap Well ? No		2. Well Type New Well							
Heat Exchange ___ # of drillholes						Hicap Property ? No		of previous unique well # constructed in							
Hicap Potable ?						Reason for replaced or reconstructed well ?									
4. Potential Contamination Sources - ON REVERSE SIDE						Construction Type Drilled									
5. Drillhole Dimensions and Construction Method												8. Geology			
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)		
8 Surface 40			Rotary - Mud Circulation						- - C -		CLAY		Surface 6		
6 40 200			Rotary - Air						K D Q -		DC/BLACK GRANITE		6 10		
			Rotary - Air & Foam						K H Q -		HARD BLACK GRANITE		10 200		
			Drill-Through Casing Hammer												
			Reverse Rotary												
			Cable-tool Bit ___ in. dia...												
			Dual Rotary												
			Temp. Outer Casing 10in. dia												
			Removed? 10depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is	
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		15 ft. below ground surface		18 in. above grade				
6			FEMCO 530 6.625 18.9 #WELDED USA .280 WALL				Surface 40		10. Pump Test		Developed ? Yes				
Dia. (in.)			Screen type, material & slot size				From (ft.) To (ft.)		Pumping level 180 ft. below surface		Disinfected ? Yes				
									Pumping at 3 GP M for 12 Hrs.		Capped ? Yes				
									Pumping Method ?						
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?			
Method DISPLACEMENT												Filled & Sealed Well(s) as needed?			
Kind of Sealing Material			From (ft.) To (ft.)		# Sacks Cement										
NEAT GROUT			Surface 40		10 S										
13. Constructor / Supervisory Driller												Lic #		Date Signed	
JH														03-23-2018	
Drill Rig Operator												Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment:

Rehab Type	Rehab Date	Result Text
Hydrofracture	03/23/2018	YIELD BEFORE DRY HOLE; AFTER 3 GPM

Created On: 04-17-2018

Updated On: 04-17-2018

Review Status: