

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YZ655		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BADGER HOMES, (OLENA)						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 2146 CELTIC CT						Town of ERIN													
City HARTFORD						State WI		Zip Code 53027											
County Washington		Co. Permit #		Notification # 7088425903		Completed 04-03-2018		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) LANCE M GEHRING				Lic. # 6994		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.2684 °N -88.4068 °W				Method Code GPS008					
Address LANCE GEHRING WELL DRILLING TWIN LAKES WI 53181				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 6 9 N 18 E		2. Well Type New Well											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.8				Reason for replaced or reconstructed well ?									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
9		Surface		87		<u>Yes</u> Rotary - Mud Circulation <u>No</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 14in. dia <u>Yes</u> Removed? 2depth ft. (If NO explain on back side)						- - Z - CLAY GRAVEL R - G - GRAVEL RED		Surface 81		81 87			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		35 ft. below ground surface				14 in. above grade					
5		200LB PVC 1120 SDR 21F480 SOLVENT WELD				Surface		83		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 60 ft. below surface Pumping at 20 GP M for 2 Hrs. Pumping Method ?									
5		STAINLESS STEEL #20				83		87											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method PRESSURE PUMP																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				No					
CETCO				Surface		83		9 S		NONE									
13. Constructor / Supervisory Driller												Lic #		Date Signed					
LG														04-03-2018					
Drill Rig Operator												Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		175	Septic or Holding, or POWTS Tank		180

Comment:

Created On: 05-07-2018

Updated On: 05-07-2018

Review Status: