

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YZ657		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner MAX, MARTY						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 2410 HAERLE						Village of TWIN LAKES															
City TWIN LAKES						State WI		Zip Code 53181													
County Kenosha		Co. Permit #		Notification # 7123781801		Completed 04-05-2018		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) LANCE M GEHRING				Lic. # 6994		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.5059 °N -88.2774 °W				Method Code GPS008							
Address LANCE GEHRING WELL DRILLING TWIN LAKES WI 53181				Well Plan Approval #				NE NW		Section 32		Township 1 N		Range 19 E							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 1.1		2. Well Type Replacement															
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # constructed in													
						Hicap Property ? No		Reason for replaced or reconstructed well ? OLD POINT													
						Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
9		Surface		48		<u>Yes</u> Rotary - Mud Circulation <u>No</u>						- - C -		CLAY		Surface		22			
						Rotary - Air						- - G -		GRAVEL		22		48			
						Rotary - Air & Foam															
						Drill-Through Casing Hammer															
						Reverse Rotary															
						Cable-tool Bit ___ in. dia...															
						Dual Rotary															
						<u>Yes</u> Temp. Outer Casing 14in. dia															
						<u>Yes</u> Removed? 2depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		2 ft. below ground surface				14 in. above grade							
5		200LB PVC 1170 SDR 21F480 SOLVENT WELD				Surface		44		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 20 ft. below surface				Disinfected ? Yes							
5		STAINLESS STEEL 20 SLOT				44		48		Pumping at 20 GP M for 2 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material Method PRESSURE PUMP						Pumping Method ?		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed							
CETCO		Surface		44		5 S		LG						04-05-2018							
						Drill Rig Operator		Lic or Reg #		Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Collector Sewer - San or Storm		60	Sewer - Building Sanitary		10

Comment:

Created On: 05-07-2018

Updated On: 08-23-2019

Review Status: