

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YZ659		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner JOHNSON						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address 2506 SHERMAN LN						Town of RANDALL																	
City TWIN LAKES						State WI		Zip Code 53181															
County Kenosha		Co. Permit #		Notification # 6990481006		Completed 04-09-2018		Subdivision Name				Lot # Block #											
Well Constructor (Business Name) LANCE M GEHRING				Lic. # 6994		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.5048 °N -88.2298 °W				Method Code GPS008									
Address LANCE GEHRING WELL DRILLING TWIN LAKES WI 53181				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 34 1 N 19 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled															
				Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
9		Surface		57		<u>Yes</u> Rotary - Mud Circulation <u>No</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 14in. dia <u>Yes</u> Removed? 2depth ft. (If NO explain on back side)						- - C - CLAY				Surface		8					
												- - G - GRAVEL				8		27					
												- - C - CLAY				27		32					
												- - G - GRAVEL				32		57					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		6 ft. below ground surface				14 in. above grade									
5		200LB PVC 1120 SDR 21F480 SOLVENT WELD				Surface		47		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 25 ft. below surface				Disinfected ? Yes									
5		STAINLESS STEEL #20				47		57		Pumping at 25 GP M for 2 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method PRESSURE PUMP																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?													
CETCO				Surface		47		4 S		NONE													
13. Constructor / Supervisory Driller								Lic #		Date Signed													
LG										04-09-2018													
Drill Rig Operator								Lic or Reg #		Date Signed													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		84	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 05-14-2018

Updated On: 08-23-2019

Review Status: