

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YZ839		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner MAJESTIC BUILDERS LLC						Phone # (262)227-7975							
Mailing Address 5025 MONCHES RD													
City COLGATE				State WI		Zip Code 53017							
County Washington		Co. Permit #		Notification # 8175284401		Completed 10-13-2020		1. Well Location				Fire # (if avail.) 251	
Village of RICHFIELD								Street Address or Road Name and Number 251 HUNTER TRL					
Subdivision Name HUNTER HILLS				Lot #		Block #							
Well Constructor (Business Name) STENERSON, KARL I				Lic. # 368		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.1992 °N -88.1908 °W			
Address STENERSON WELL DRILLING N8101 BAYVIEW RD HORICON WI 53032				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW SE Section Township Range		or Govt Lot # 36 9 N 19 E			
Hicap Permanent Well #		Common Well #		Specific Capacity 1		2. Well Type New Well							
3. Well serves 1 # of HOME						Reason for replaced or reconstructed well ? NEW HOME							
Private, potable						Hicap Well ? No							
Heat Exchange ___ # of drillholes						Hicap Property ? No							
						Hicap Potable ? No							
						Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology				
9 Surface 101			Yes Rotary - Mud Circulation			No			Geology Codes R C R-RED C-CLAY Surface 28				
6 101 246			No Rotary - Air			Yes			C C-CLAY 28 89				
			No Rotary - Air & Foam			No			C G C-CLAY G-W/GRAVEL/STONES 89 93				
			No Drill-Through Casing Hammer						C C-CLAY 93 101				
			No Reverse Rotary						L L-LIMESTONE/DOLOMITE 101 246				
			No Cable-tool Bit ___ in. dia...			No							
			No Dual Rotary			No							
			No Temp. Outer Casing ___ in. dia										
			No Removed? ___ depth ft. (If NO explain on back side)										
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
6		NEW 18.97 LB STEEL A-53 GR B PE W/SHOE WHEATLAND				Surface		101		45 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
										14 in. above grade			
										10. Pump Test			
										Developed ? Yes			
										Disinfected ? Yes			
										Capped ? Yes			
										Pumping level 60 ft. below surface			
										Pumping at 15 GP M for 1 Hrs.			
										Pumping Method ? Airlift			
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
SODIUM BENTONITE		Surface		101		S							
12. Notified Owner of need to fill & seal ? Yes													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
KS				Lic # 368				Date Signed 11-24-2020					
Drill Rig Operator				Lic or Reg #				Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		70	POWTS dispersal component (soil absorption unit or mound)		65
			Sewer - Building Sanitary		75

Comment:

Created On: 12-10-2020

Updated On: 05-28-2021

Review Status: APPROVED