

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YZ840		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner MARK BOHN CARPENTRY						Phone # (262)224-0161		1. Well Location				Fire # (if avail.)					
Mailing Address 4802 BKERSHIRE CT						Town of LEROY						W3087					
City WEST BEND						State WI		Zip Code 53095				Street Address or Road Name and Number					
W3087 FARMERSWILL RD						Subdivision Name				Lot #		Block #					
County Dodge		Co. Permit #		Notification # 8195156001		Completed 11-20-2020		Latitude / Longitude in Decimal Degree (DD)				Method Code					
Well Constructor (Business Name) STENERSON, KARL I						Lic. # 368		Facility ID # (Public Wells)				43.5577 °N -88.5496 °W		GPS008			
Address STENERSON WELL DRILLING N8101 BAYVIEW RD HORICON WI 53032						Well Plan Approval #		NW NE		Section 35		Township 13 N		Range 16 E			
						Approval Date (mm-dd-yyyy)		or Govt Lot #		35		13 N		16 E			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2		2. Well Type New Well									
Reason for replaced or reconstructed well ?						NEW HOME											
3. Well serves 1 # of HOME						Hicap Well ? No		Construction Type Drilled									
Private, potable						Hicap Property ? No											
Heat Exchange ___ # of drillholes						Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		295		Yes Rotary - Mud Circulation		No		C		C-CLAY		Surface		8	
6		295		580		No Rotary - Air		Yes		L		L-LIMESTONE/DOLOMITE		8		61	
						No Rotary - Air & Foam		No		H		H-SHALE		61		285	
						No Drill-Through Casing Hammer				L		L-LIMESTONE/DOLOMITE		285		520	
						No Reverse Rotary				N		N-SANDSTONE		520		580	
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is			
6		NEW 18.99 LB STEEL A-53 GR B WHEATLAND				Surface		295		185 ft. below ground surface				14 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes			
										Pumping level 265 ft. below surface				Disinfected ? Yes			
										Pumping at 15 GP M for 2 Hrs.				Capped ? Yes			
										Pumping Method ? Airlift							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Yes					
Method		BRADENHEAD															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
NEAT CEMENT GROUT		Surface		295		58 S		Filled & Sealed Well(s) as needed? Yes									
												13. Constructor / Supervisory Driller					
												Lic #		Date Signed			
												KS		368		11-23-2020	
												Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Septic or Holding, or POWTS Tank		100
			Sewer - Building Sanitary		80

Comment:

Created On: 12-10-2020

Updated On: 05-28-2021

Review Status: APPROVED