

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZA341		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner VORDERBRUGGEN, STEPHEN						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 27130 89TH ST								Town of FIFIELD				N12983									
City SALAM						State WI		Zip Code 53168				Street Address or Road Name and Number LONE PINE RD									
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #							
Price				8817160201		09-25-2023		WHISPERING PINES				2									
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code									
HOLT, JOHN A				250				45.84411 °N -90.38494 °W				SCR006									
Address JOHN HOLT WELL DRILLING N15485 TOWN HALL RD PARK FALLS WI 54552-9310				Well Plan Approval #		SE SW		Section		Township		Range									
				Approval Date (mm-dd-yyyy)		or Govt Lot #		20		39 N		1 E									
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
						0.5															
3. Well serves 1 # of CAMPER						Hicap Well ? No															
Private, potable						Hicap Property ? No															
Heat Exchange ___ # of drillholes						Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		53		No Rotary - Mud Circulation				No		X		X-SAND & CLAY		Surface		15			
						No Rotary - Air				No		S		S-SAND		15		50			
						No Rotary - Air & Foam				No		Y		Y-SAND & GRAVEL		50		53			
						Yes Drill-Through Casing Hammer															
						No Reverse Rotary															
						No Cable-tool Bit ___ in. dia...				No											
						No Dual Rotary				No											
						No Temp. Outer Casing ___ in. dia															
						No Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				20 in. above grade							
6		ASTM A53B				Surface		53		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 40 ft. below surface				Disinfected ? Yes							
										Pumping at 10 GP M for 10 Hrs.				Capped ? Yes							
										Pumping Method ? Test Pump											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No							
Method MOUNDED																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No											
GRANULAR BENTONITE				Surface																	
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														JH				250		02-29-2024	
														Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Type	Qualifier	Distance
Privy		30

Comment: JEFFREY HOLT SIGNED AS RIG OPERATOR
3/4/24 DNR APPROXIMATED COORDINATES - NOT PROVIDED BY WELL DRILLER

Created On: 03-04-2024 Updated On: 03-26-2024 Review Status: APPROVED