Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZA341

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: VORDERBRUGGEN, STEPHEN	Phone #
Mailing Address: 27130 89TH ST	
City: SALAM	State: WI — Zip Code: 53168
County: Price	Co. Permit #: — Notification #: 8817160201 — Completed: 09-25-2023
Well Constructor (Business Name): HOLT, JOHN A	Lic. #: 250 — Facility ID # (Public Wells):
Address: JOHN HOLT WELL DRILLING N15485 TOWN HALL RD PARK FALLS WI 54552-9310	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5

1. Well Location

Town of FIFIELD	Fire # (if avail.): N12983
Street Address or Road Name and Number: LONE PINE RD	
Subdivision Name: WHISPERING PINES	Lot #: 2 — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.84411 °N -90.38494 °W	Method Code: SCR006
SE SW or Govt Lot #: — Section: 20 — Township: 39 N — Range: 1 E	

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of CAMPER

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	53

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
X	X-SAND & CLAY	Surface	15
S	S-SAND	15	50
Y	Y-SAND & GRAVEL	50	53

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B	Surface	53
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 10 GP M for 10 Hrs.

Pumping Method ? Test Pump

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH	250	02-29-2024
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Privy		30

Comment: JEFFREY HOLT SIGNED AS RIG OPERATOR

3/4/24 DNR APPROXIMATED COORDINATES - NOT PROVIDED BY WELL DRILLER

Created On: 03-04-2024 Updated On: 03-26-2024 Review Status: APPROVED