

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZA369		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner HUBERTZ, CRAIG						Phone # (262)215-3502		1. Well Location				Fire # (if avail.)							
Mailing Address 2588 NORTH SHORE DR						Town of DELAVAN													
City DELAVAN						State WI		Zip Code 53115											
County Walworth		Co. Permit #		Notification # 7238292701		Completed 09-18-2018		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) HINTZ, LARRY D				Lic. # 508		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.6041 °N -88.6191 °W									
Address LARRY HINTZ WELL DRILLING N5273 CTY TRK M DELAVAN WI 53115-9610				Well Plan Approval #		Method Code GPS008													
						SW NW Section Township Range or Govt Lot # 28 2 N 16 E													
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type New Well									
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No				of previous unique well # constructed in									
Hicap Potable ? Yes						Reason for replaced or reconstructed well ?													
3. Well serves 1 # of HOME				Private, potable		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)						
10 Surface 4			No Rotary - Mud Circulation No						C C-CLAY		Surface 4								
6 4 55			No Rotary - Air No						G G-GRAVEL/STONES		4 37								
			No Rotary - Air & Foam No						Z Z-CLAY & GRAVEL		37 45								
			No Drill-Through Casing Hammer						S S-SAND		45 55								
			No Reverse Rotary																
			Yes Cable-tool Bit 10in. dia... No																
			No Dual Rotary No																
			No Temp. Outer Casing ___ in. dia																
			No Removed? ___ depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		25 ft. below ground surface				18 in. above grade							
6		BLK STEEL P-E 18.97 A53 WHEATLAND TUBE				Surface 51		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		Pumping level 25 ft. below surface				Disinfected ? Yes							
6		STAINLESS STEEL 15				51 55		Pumping at 20 GP M for 10 Hrs.				Capped ? Yes							
								Pumping Method ? Test Pump											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No					
Method																			
Kind of Sealing Material				From (ft.) To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No											
CLAY SLURRY				Surface 4		S													
13. Constructor / Supervisory Driller														Lic #		Date Signed			
LH														508		09-18-2018			
Drill Rig Operator														Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		110	Building Drain - Sanitary		30
Sewer - Collector - Storm		95	Sewer - Building Sanitary		35

Comment:

Created On: 11-12-2018

Updated On: 11-14-2018

Review Status: APPROVED