

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZA370		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner TUESCHAR, JEFF						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address OVERLOOK DR LOT 40								Town of LAFAYETTE													
City ELKHORN						State WI		Zip Code 53121													
County Walworth		Co. Permit #		Notification # 7264715701		Completed 07-18-2018		Subdivision Name EVERGREEN				Lot # 40									
Well Constructor (Business Name) HINTZ, LARRY D				Lic. # 508		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.7103 °N -88.5388 °W											
						Well Plan Approval #				Method Code GPS008											
Address LARRY HINTZ WELL DRILLING N5273 CTY TRK M DELAVAN WI 53115-9610						Approval Date (mm-dd-yyyy)				NW NW Section Township Range or Govt Lot # 19 3 N 17 E											
Hicap Permanent Well #		Common Well #		Specific Capacity 2						2. Well Type New Well											
										of previous unique well # constructed in											
										Reason for replaced or reconstructed well ?											
3. Well serves 1 # of HOME						Hicap Well ? No															
Private, potable						Hicap Property ? No															
Heat Exchange ___ # of drillholes						Hicap Potable ? Yes		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		6		No Rotary - Mud Circulation				No		C		C-CLAY		Surface		6			
6		6		85		No Rotary - Air				No		G C		G-GRAVEL/STONES C-CLAYEY		6		27			
						No Rotary - Air & Foam				No		S		S-SAND		27		40			
						No Drill-Through Casing Hammer						C		C-CLAY		40		80			
						No Reverse Rotary						G		G-GRAVEL/STONES		80		85			
						Yes Cable-tool Bit 10in. dia...				No											
						No Dual Rotary				No											
						No Temp. Outer Casing ___ in. dia															
						No Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification				From (ft.)		To (ft.)		25 ft. below ground surface				18 in. above grade							
		Manufacturer & Method of Assembly																			
6		[E 18.97 A53 BLK STEEL (WHEATLAND TUBE)				Surface		82													
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes							
6		STAINLESS STEEL (15)				82		85		Pumping level 35 ft. below surface				Disinfected ? Yes							
										Pumping at 20 GP M for 10 Hrs.				Capped ? Yes							
										Pumping Method ? Test Pump											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No							
		Method																			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				Filled & Sealed Well(s) as needed?				No							
CLAY SLURRY		Surface		6		S															
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														LH		508		08-02-2018			
														Drill Rig Operator		Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: SEPTIC/SEWER NOT PRESENT

Created On: 09-06-2018

Updated On: 10-02-2018

Review Status: APPROVED