

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZA457		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner GLAPINSKI, BOB						Phone # (715)470-4888		1. Well Location				Fire # (if avail.)					
Mailing Address 2123882 DEER PATH LN						Town of REID											
City HATLEY						State WI		Zip Code 54440									
County Marathon		Co. Permit #		Notification # 7233185101		Completed 06-15-2018		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) DREWS, EDWARD J				Lic. # 327		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.7937 °N -89.409 °W							
Address DREWS WELL DRLG R15289 RINGLE AVE RINGLE WI 54471				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 28 27 N 9 E		2. Well Type New Well									
				Approval Date (mm-dd-yyyy)				of previous unique well # constructed in									
Hicap Permanent Well #		Common Well #		Specific Capacity 1.5		Reason for replaced or reconstructed well ?											
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled											
Private, potable				Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.) 6		From (ft.) Surface		To (ft.) 38		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
						No Rotary - Mud Circulation		No		Y G		Y-SAND & GRAVEL G-W/GRAVEL/STONES		Surface 27			
						No Rotary - Air		No		Y		Y-SAND & GRAVEL		27 31			
						No Rotary - Air & Foam		No		G		G-GRAVEL/STONES		31 38			
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is	
Dia. (in.) 6		Material, Weight, Specification HYUNDAI A53B 18.97 WELDED.				From (ft.) Surface		To (ft.) 38		20 ft. below ground surface				18 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes			
										Pumping level 30 ft. below surface				Disinfected ? Yes			
										Pumping at 15 GP M for 1 Hrs.				Capped ? Yes			
										Pumping Method ? Test Pump							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No					
Method MOUNDED																	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				Filled & Sealed Well(s) as needed?				No			
CETCO #8		Surface				1 S											
13. Constructor / Supervisory Driller												Lic #		Date Signed			
EJD												327		06-20-2018			
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	110	Septic or Holding, or POWTS Tank	>	60

Comment:

Created On: 08-09-2018

Updated On: 08-28-2018

Review Status: APPROVED