

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZA509		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MARK BOHN CARPENTRY LLC						Phone # (262)224-0161		1. Well Location				Fire # (if avail.)							
Mailing Address 4802 BERKSHIRE CT						Town of KEWASKUM													
City WEST BEND						State WI		Zip Code 53095											
County Washington		Co. Permit #		Notification # 8094702701		Completed 09-04-2020		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) STENERSON, KARL I				Lic. # 368		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.5345 °N -88.2167 °W									
Address STENERSON WELL DRILLING N8101 BAYVIEW RD HORICON WI 53032				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 3 12 N 19 E		2. Well Type New Well											
				Approval Date (mm-dd-yyyy)				of previous unique well # constructed in											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		Reason for replaced or reconstructed well ?													
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled													
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		243		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				C		C-CLAY		Surface		140			
										X G		X-SAND & CLAY G-W/GRAVEL/STONES		140		162			
										L		L-LIMESTONE/DOLOMITE		162		243			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		25 ft. below ground surface				16 in. above grade					
6		NEW 18.99 LB STEEL A53 GR B PE W/SHOE WHEATLAND				Surface		162		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 80 ft. below surface				Disinfected ? Yes					
										Pumping at 15 GP M for 2 Hrs.				Capped ? Yes					
										Pumping Method ? Airlift									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Yes							
Method												Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement													
CRUMBLES		Surface		162		S						13. Constructor / Supervisory Driller				Lic #		Date Signed	
												KS		368		09-17-2020			
										Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Sewer - Building Sanitary		90
			Septic or Holding, or POWTS Tank		100

Comment:

Created On: 12-10-2020

Updated On: 06-01-2021

Review Status: APPROVED