

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZA510		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner MARK BOHN CARPENTRY Phone # (262)224-0161						1. Well Location Fire # (if avail.) 5495						
Mailing Address 4812 BERKSHIRE CT City WEST BEND State WI Zip Code 53032						Town of TRENTON Street Address or Road Name and Number 5495 S CHURCH RD						
County Washington		Co. Permit #		Notification # 8119695601		Completed 10-10-2020		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) STENERSON, KARL I				Lic. # 368		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.3893 °N -88.1009 °W			Method Code GPS008	
Address STENERSON WELL DRILLING N8101 BAYVIEW RD HORICON WI 53032				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 28 11 N 20 E		2. Well Type New Well				
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4		Reason for replaced or reconstructed well ? NEW HOME				
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled						
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock			
8		Surface		126		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						
8. Geology												
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
C		C-CLAY				Surface		124				
G		G-GRAVEL/STONES				124		126				
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)				
6		NEW 18.97 LB STEEL A53 GR B PE W/SHOE WHEATLAND				Surface		126				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)				
7. Grout or Other Sealing Material												
Method												
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				
SODIUM BENTONITE SLURRY				Surface		124		S				
9. Static Water Level												
30 ft. below ground surface												
10. Pump Test												
Pumping level 70 ft. below surface												
Pumping at 15 GP M for 1 Hrs.												
Pumping Method ? Airlift												
11. Well Is												
20 in. above grade												
Developed ? Yes												
Disinfected ? Yes												
Capped ? Yes												
12. Notified Owner of need to fill & seal ? Yes												
Filled & Sealed Well(s) as needed? Yes												
13. Constructor / Supervisory Driller												
Lic #				Date Signed								
KS				368				10-21-2020				
Drill Rig Operator				Lic or Reg #				Date Signed				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Sewer - Building Sanitary		120
			Septic or Holding, or POWTS Tank		150

Comment:

Created On: 12-10-2020

Updated On: 01-15-2021

Review Status: APPROVED