Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZA601

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MURLOT, HANS			Phone #
Mailing Address: 7746 CO RD E			
City: WESTFIELD	State: WI	Zip Code: 53964	
County: Marquette	Co. Permit #:	Notification #: 7155234801	Completed: 04-24-2018

Well Constructor (Business Name): RODNEY J REICHHOFF	Lic. #: 7202	Facility ID # (Public Wells):	
Address: W8740 EVERGREEN DR OXFORD WI 53952		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.8	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of WESTFIELD

Fire # (if avail.): 7746

Street Address or Road Name and Number: 7746 CO RD E

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 43.8837 °N -89.5435 °W
Method Code: GCD013

SW	NW	Section	Township	Range
or Govt Lot #		9	16 N	8 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
DRIVEN POINT NOT TO CODE

Construction Type: Jetted

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	42
1.25	42	45

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 1.25in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	-	S	-	YELLOW SAND	Surface	20
-	-	Y	-	SAND & GRAVEL	20	45

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND ERW ASTM A53 COUPLED 3.75#	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	STAINLESS STEEL 80 GA	42	45

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
12 ft. below ground surface

10. Pump Test
Pumping level 24 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
28 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		04-25-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Septic or Holding, or POWTS Tank		48

Comment:

Created On: 05-07-2018 Updated On: 04-08-2020 Review Status: