Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZA679

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: AMIDON, RODNEY	Phone #: (715)946-3114
Mailing Address: W421 CO RD Z	
City: MONDOVI	State: WI — Zip Code: 54755
County: Buffalo	Co. Permit #:
Notification #: 7427538001	Completed: 11-03-2018
Well Constructor (Business Name): PELKE GLEN PLBG HTG & WELL DRLG INC	Lic. #: 131
Facility ID # (Public Wells):	
Address: 835 RIVERSIDE AVE MONDOVI WI 54755-1443	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.3	

1. Well Location

Town of DOVER	Fire # (if avail.): W405
Street Address or Road Name and Number: CO RD Z	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.4898 °N -91.6109 °W	Method Code: GPS008

SE	NE	Section	Township	Range
or Govt Lot #		8	23 N	10 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	6
6	6	115

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		I-SOIL-ORGANIC	Surface	2
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	2	85
G	Q	S		G-GRAY Q-CAVING S-SAND	85	95
G	H	N		G-GRAY H-HARD/FIRM N-SANDSTONE	95	115

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK, T&C ASTM A-53 GRB. (LTV STEEL) 19.45LBS A F SEIDEMAN FLC	Surface	100
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 75 ft. below surface

Pumping at 12 GP M for 2.5 Hrs.

Pumping Method ? Test Pump

11. Well Is

30 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method HAND FED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY	Surface	6	S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DP	6343	11-19-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Septic or Holding, or POWTS Tank	>	30

Comment:

Created On: 07-17-2019 Updated On: 07-17-2019 Review Status: APPROVED