

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZA679		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner AMIDON, RODNEY						Phone # (715)946-3114		1. Well Location				Fire # (if avail.)							
Mailing Address W421 CO RD Z						Town of DOVER						W405							
City MONDOVI						State WI		Zip Code 54755				Street Address or Road Name and Number CO RD Z							
County Buffalo		Co. Permit #		Notification # 7427538001		Completed 11-03-2018		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) PELKE GLEN PLBG HTG & WELL DRLG INC				Lic. # 131		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.4898 °N -91.6109 °W				Method Code GPS008					
Address 835 RIVERSIDE AVE MONDOVI WI 54755-1443				Well Plan Approval # Approval Date (mm-dd-yyyy)		SE NE		Section 8		Township 23 N		Range 10 W							
						or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3				2. Well Type New Well									
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ?									
Hicap Potable ? No										Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)				
10 Surface 6			No Rotary - Mud Circulation No								T Q S I SOIL-ORGANIC		Surface 2						
6 6 115			No Rotary - Air No								T Q S T-TAN/BROWN Q-CAVING S-SAND		2 85						
			No Rotary - Air & Foam No								G Q S G-GRAY Q-CAVING S-SAND		85 95						
			No Drill-Through Casing Hammer								G H N G-GRAY H-HARD/FIRM N-SANDSTONE		95 115						
			No Reverse Rotary																
			Yes Cable-tool Bit 6in. dia... No																
			No Dual Rotary No																
			No Temp. Outer Casing ___ in. dia																
			No Removed? ___ depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				30 in. above grade					
6		NEW BLK, T&C ASTM A-53 GRB. (LTV STEEL) 19.45LBS A F SEIDEMAN FLC				Surface		100		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 75 ft. below surface				Disinfected ? Yes					
										Pumping at 12 GP M for 2.5 Hrs.				Capped ? Yes					
										Pumping Method ? Test Pump									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No					
Method HAND FED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No									
DRILL SLURRY				Surface		6		S											
13. Constructor / Supervisory Driller														Lic #		Date Signed			
DP														6343		11-19-2018			
Drill Rig Operator														Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Septic or Holding, or POWTS Tank	>	30

Comment:

Created On: 07-17-2019

Updated On: 07-17-2019

Review Status: APPROVED