Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZA681

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ADAIR, ROBIN	Phone #: (414)788-1293
Mailing Address: 8181 7 MILE RD	
City: RACINE	State: WI — Zip Code: 53126

County	Co. Permit #	Notification #	Completed
Trempealeau	53643	8157719001	09-25-2020

1. Well Location

Town of BURNSIDE

Fire # (if avail.)

Street Address or Road Name and Number: W27706 COUNTY RD O

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
PELKE GLEN PLBG HTG & WELL DRLG INC	131	

Latitude / Longitude in Decimal Degree (DD): 44.4159 °N -91.5021 °W — Method Code: GPS008

Well Plan Approval #

SE NW or Govt Lot #	Section	Township	Range
	5	22 N	9 W

Address: 835 RIVERSIDE AVE, MONDOVI WI 54755-1443

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.5

Reason for replaced or reconstructed well ?

3. Well serves 1 # of CABIN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	30
6	30	95

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	V	I		V-NON-CAVING I-SOIL-ORGANIC	Surface	2
T	V	N		T-TAN/BROWN V-NON-CAVING N-SANDSTONE	2	24
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	24	95

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK CASING A.F. SELDEMAN CO. INC 19.45LBS FT	Surface	52
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

50 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT	Surface	30	17 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DP	6343	09-25-2020
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DP	6343	09-25-2020

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 11-23-2020 Updated On: 05-04-2021 Review Status: APPROVED