Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZA683

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KKJ PROPERTIES LLC, (SPANGBERG, BRIAN)	Phone #: (715)579-4289
Mailing Address: 4701 OAK BLUFF CT	
City: EAU CLAIRE	State: WI Zip Code: 54701

County	Co. Permit #	Notification #	Completed
Trempealeau	54234	8175862901	10-13-2020

Well Constructor (Business Name): PELKE GLEN PLBG HTG & WELL DRLG INC	Lic. #: 131
Address: 835 RIVERSIDE AVE MONDOVI WI 54755-1443	
Hicap Permanent Well #	Common Well #
Facility ID # (Public Wells)	
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Specific Capacity: 0.8	

1. Well Location

Fire # (if avail.)

Town of HALE

Street Address or Road Name and Number: N44652 LEE RD STRUM WI 54770

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.4887 °N -91.3881 °W	GPS008

SE NE or Govt Lot #	Section	Township	Range
	7	23 N	8 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of CABIN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	30
6	30	160

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		I-SOIL-ORGANIC	Surface	2
	V	I		V-NON-CAVING I-SOIL-ORGANIC	2	18
T	V	N		T-TAN/BROWN V-NON-CAVING N-SANDSTONE	18	150
G	V	N		G-GRAY V-NON-CAVING N-SANDSTONE	150	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	19.46 LBS PER FOOT BLACK CASING AF SEILEMAN CO	Surface	84
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT	Surface	30	15 S

9. Static Water Level

120 ft. below ground surface

10. Pump Test

Pumping level 140 ft. below surface

Pumping at 15 GP M for 3 Hrs.

Pumping Method ? Test Pump

11. Well Is

30 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DP	6343	10-13-2020
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 11-02-2020 Updated On: 04-09-2021 Review Status: APPROVED