

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZA683		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner KKJ PROPERTIES LLC, (SPANGBERG, BRIAN)						Phone # (715)579-4289		1. Well Location				Fire # (if avail.)			
Mailing Address 4701 OAK BLUFF CT						Town of HALE									
City EAU CLAIRE						State WI		Zip Code 54701							
County Trempealeau		Co. Permit # 54234		Notification # 8175862901		Completed 10-13-2020		Street Address or Road Name and Number N44652 LEE RD STRUM WI 54770							
Well Constructor (Business Name) PELKE GLEN PLBG HTG & WELL DRLG INC						Lic. # 131		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.4887 °N -91.3881 °W		Method Code GPS008	
Address 835 RIVERSIDE AVE MONDOVI WI 54755-1443						Well Plan Approval #		SE NE		Section 7		Township 23 N		Range 8 W	
								or Govt Lot #							
Approval Date (mm-dd-yyyy)						2. Well Type New Well									
Hicap Permanent Well #						Common Well #		Specific Capacity 0.8				of previous unique well # constructed in			
3. Well serves 1 # of CABIN						Hicap Well ? No		Reason for replaced or reconstructed well ?							
Private, potable						Hicap Property ? No									
Heat Exchange ___ # of drillholes						Hicap Potable ? No		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 30			No Rotary - Mud Circulation No												
6 30 160			No Rotary - Air No												
			No Rotary - Air & Foam No												
			No Drill-Through Casing Hammer												
			No Reverse Rotary												
			Yes Cable-tool Bit 10in. dia... No												
			No Dual Rotary No												
			No Temp. Outer Casing ___ in. dia												
			No Removed? ___ depth ft. (If NO explain on back side)												
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
I				I-SOIL-ORGANIC				Surface		2					
V I				V-NON-CAVING I-SOIL-ORGANIC				2		18					
T V N				T-TAN/BROWN V-NON-CAVING N-SANDSTONE				18		150					
G V N				G-GRAY V-NON-CAVING N-SANDSTONE				150		160					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		19.46 LBS PER FOOT BLACK CASING AF SEILEMAN CO				Surface		84							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
PORTLAND CEMENT				Surface		30		15 S							
9. Static Water Level															
120 ft. below ground surface															
10. Pump Test															
Pumping level 140 ft. below surface															
Pumping at 15 GP M for 3 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
30 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
DP 6343				10-13-2020											
Drill Rig Operator				Lic or Reg # Date Signed											

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 11-02-2020

Updated On: 04-09-2021

Review Status: APPROVED