

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZB137		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MEYERS, BARRY						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 11850 52ND ST S						Town of SARATOGA									
City WISCONSIN RAPIDS						State WI		Zip Code 54494				Street Address or Road Name and Number 11850 52ND ST S			
County Wood		Co. Permit #		Notification # 7800944001		Completed 10-17-2019		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) ERON&GEE/HERMANS PLBG & HTG INC				Lic. # 2900		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.2856 °N -89.7622 °W				Method Code GPS008	
Address 1111 ALTON ST WISCONSIN RAPIDS WI 54495-3398				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 23 21 N 6 E				2. Well Type Replacement					
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ? FAILING									
3. Well serves 1 # of HOME						Hicap Well ? No									
Private, potable						Hicap Property ? No									
Heat Exchange ___ # of drillholes						Hicap Potable ? No		Construction Type Driven Point							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method												8. Geology			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
2		Surface		30		No Rotary - Mud Circulation				No					
						No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
6. Casing, Liner, Screen				No Temp. Outer Casing ___ in. dia		9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		14 ft. below ground surface					
2		GALVANIZED A53				Surface		27		10. Pump Test					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes					
2		10 SLOT SS				27		30		Disinfected ? Yes					
7. Grout or Other Sealing Material						Pumping level ___ ft. below surface				Capped ? Yes					
Method						Pumping at ___ GP for ___ Hrs.				Pumping Method ?					
						12. Notified Owner of need to fill & seal ? No									
						Filled & Sealed Well(s) as needed? Yes									
						13. Constructor / Supervisory Driller									
						Lic #									
						Date Signed									
JPE						6177									
Drill Rig Operator						10-22-2019									
						Lic or Reg #									
						Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Sewer - Building Sanitary		30
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 01-08-2020

Updated On: 01-08-2020

Review Status: APPROVED