

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZB145		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner C&D AUTOMATED						Phone # (262)629-1535		1. Well Location				Fire # (if avail.)				
Mailing Address 6561 HWY 175								Town of ADDISON				6561				
City ALLENTON						State WI		Zip Code 53002				Street Address or Road Name and Number 6561 HWY 175				
County Washington		Co. Permit #		Notification # 7811214701		Completed 11-19-2019		Subdivision Name				Lot # Block #				
Well Constructor (Business Name) UMLAND, RICHARD L				Lic. # 89		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.4311 °N -88.3798 °W				Method Code GPS008				
Address RICKS WELL & PUMP SERVICE W2721 HWY 33 MAYVILLE WI 53050				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 8 11 N 18 E		2. Well Type New Well				of previous unique well # constructed in				
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1		Reason for replaced or reconstructed well ?		Construction Type Drilled				Reason for replaced or reconstructed well ?				
3. Well serves 1 # of WAREHOUSE Non-community Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? Yes												
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method																
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology							
8.75 Surface 154			Yes Rotary - Mud Circulation No			T P T-TAN/BROWN P-HARDPAN Surface 18			G P G-GRAY P-HARDPAN 18 84							
6 154 217			No Rotary - Air Yes			G S G-GRAY S-SAND 84 92			G C G-GRAY C-CLAY 92 154							
			No Rotary - Air & Foam No			L L L-LIMESTONE/DOLOMITE 154 217										
			No Drill-Through Casing Hammer													
			No Reverse Rotary													
			No Cable-tool Bit ___ in. dia... No													
			No Dual Rotary No													
			No Temp. Outer Casing ___ in. dia													
			No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen																
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is				
6		BLACK PE 18.97 LBS/FT A53B WHEATLAND STEEL				Surface		155		50 ft. below ground surface		14 in. above grade				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes				
										Pumping level 120 ft. below surface		Disinfected ? Yes				
										Pumping at 7 GP M for 1 Hrs.		Capped ? Yes				
										Pumping Method ? Airlift						
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No				
Method												Filled & Sealed Well(s) as needed? No				
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller			Lic #		Date Signed	
DRILLING MUD				Surface		154				RU			89		12-08-2019	
										Drill Rig Operator			Lic or Reg #		Date Signed	
										KS			368		12-08-2019	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		53	Sewer - Building Sanitary		30
			Septic or Holding, or POWTS Tank		28

Comment:

Created On: 01-07-2020

Updated On: 01-07-2020

Review Status: APPROVED