

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZB146		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner HANEFELD, DAVE						Phone # (920)210-1182		1. Well Location				Fire # (if avail.)			
Mailing Address W6177 SWAN RD						Town of BURNETT						W6167			
City BURNETT						State WI		Zip Code 53922				Street Address or Road Name and Number W6177 SWAN RD			
County Dodge		Co. Permit #		Notification # 7828111601		Completed 11-19-2019		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) UMLAND, RICHARD L				Lic. # 89		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.4877 °N -88.7074 °W				Method Code GPS008	
Address RICKS WELL & PUMP SERVICE W2721 HWY 33 MAYVILLE WI 53050				Well Plan Approval #		NE NE		Section 28		Township 12 N		Range 15 E		or Govt Lot #	
Hicap Permanent Well #				Common Well #		Specific Capacity 2				2. Well Type New Well					
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ?					
Private, potable				Hicap Potable ? Yes		Construction Type Drilled									
3. Well serves 1 # of HOME															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8.75		Surface		41		Yes Rotary - Mud Circulation				No					
6		41		87		No Rotary - Air				Yes					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		BLACK PE 18.97 LBS/FT A-53 G-B WHEATLAND STEEL				Surface		42							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method BRADENHEAD															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT				Surface		41		6 S							
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
P		P-HARDPAN				Surface		24							
L		L-LIMESTONE/DOLOMITE				24		87							
9. Static Water Level															
17 ft. below ground surface															
10. Pump Test															
Pumping level 23 ft. below surface															
Pumping at 12 GP M for 1 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
15 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
RU				89		12-08-2019									
Drill Rig Operator				Lic or Reg #		Date Signed									
KS				368		12-08-2019									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		116	Sewer - Building Sanitary		47
Building Drain - Sanitary		41	Septic or Holding, or POWTS Tank		44

Comment:

Created On: 01-09-2020

Updated On: 01-09-2020

Review Status: APPROVED