Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZB146

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HANEFELD, DAVE	Phone #: (920)210-1182
Mailing Address: W6177 SWAN RD	
City: BURNETT	State: WI Zip Code: 53922
County: Dodge	Co. Permit #:
Notification #: 7828111601	Completed: 11-19-2019
Well Constructor (Business Name): UMLAND, RICHARD L	Lic. #: 89
Facility ID # (Public Wells):	
Address: RICKS WELL & PUMP SERVICE W2721 HWY 33 MAYVILLE WI 53050	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2	

1. Well Location

Town of BURNETT	Fire # (if avail.): W6167
Street Address or Road Name and Number: W6177 SWAN RD	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 43.4877 °N -88.7074 °W	Method Code: GPS008
NE NE or Govt Lot #	Section: 28 Township: 12 N Range: 15 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? Yes

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	41
6	41	87

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
P	P-HARDPAN	Surface	24
L	L-LIMESTONE/DOLOMITE	24	87

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK PE 18.97 LBS/FT A-53 G-B WHEATLAND STEEL	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

17 ft. below ground surface

10. Pump Test

Pumping level 23 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	41	6 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RU	89	12-08-2019
Drill Rig Operator	Lic or Reg #	Date Signed
KS	368	12-08-2019

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		116
Building Drain - Sanitary		41
Sewer - Building Sanitary		47
Septic or Holding, or POWTS Tank		44

Comment:

Created On: 01-09-2020 Updated On: 01-09-2020 Review Status: APPROVED