

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZB147		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner SCHOENIKE, TOM						Phone # (920)255-3401		1. Well Location				Fire # (if avail.)									
Mailing Address PO BOX 114						Town of LEBANON						N1788									
City LEBANON						State WI		Zip Code 53047				Street Address or Road Name and Number									
County Dodge						Co. Permit #		Notification # 8085420501		Completed 07-13-2020		Subdivision Name		Lot #		Block #					
Well Constructor (Business Name) UMLAND, RICHARD L						Lic. # 89		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.2587 °N -88.6259 °W		Method Code GPS008							
Address RICKS WELL & PUMP SERVICE W2721 HWY 33 MAYVILLE WI 53050						Well Plan Approval #		SW SE		Section 8		Township 9 N		Range 16 E							
								or Govt Lot #		8		9 N		16 E							
Hicap Permanent Well #						Common Well #		Specific Capacity 1.7				2. Well Type New Well		of previous unique well #		constructed in					
3. Well serves 1 # of APARTMENT						Hicap Well ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled		Heat Exchange ___ # of drillholes		Hicap Property ? No					
Private, potable						Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)						
8.75 Surface 67			Yes Rotary - Mud Circulation				No				P P-HARDPAN		Surface 43		43						
6 67 321			No Rotary - Air				Yes				G X G-GRAY X-SAND & CLAY		43		67						
			No Rotary - Air & Foam				No				L L-LIMESTONE/DOLOMITE		67		303						
			No Drill-Through Casing Hammer								N N-SANDSTONE		303		321						
			No Reverse Rotary																		
			No Cable-tool Bit ___ in. dia...				No														
			No Dual Rotary				No														
			No Temp. Outer Casing ___ in. dia																		
			No Removed? ___ depth ft. (If NO explain on back side)																		
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		58 ft. below ground surface				29 in. above grade						
6			BLACK PE 18.97 LBS/FT A53 GR B WHEATLAND STEEL				Surface		69		10. Pump Test				Developed ? Yes						
Dia. (in.)			Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 65 ft. below surface				Disinfected ? Yes						
											Pumping at 12 GP M for 2 Hrs.				Capped ? Yes						
											Pumping Method ? Airlift										
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?				No			
Method														Filled & Sealed Well(s) as needed?				No			
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement						13. Constructor / Supervisory Driller				Lic #		Date Signed		
DRILLING MUD			Surface		67								RU		89		07-31-2020				
													Drill Rig Operator		Lic or Reg #		Date Signed				
													KS		368		07-31-2020				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		64	Building Drain - Sanitary		32
Sewer - Collector - Storm		69	Sewer - Building Sanitary		43

Comment:

Created On: 09-16-2020

Updated On: 10-22-2020

Review Status: APPROVED