Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZB147

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHOENIKE, TOM			Phone #: (920)255-3401
Mailing Address: PO BOX 114			
City: LEBANON	State: WI	Zip Code: 53047	
County: Dodge	Co. Permit #:	Notification #: 8085420501	Completed: 07-13-2020

1. Well Location

Town of LEBANON

Fire # (if avail.): N1788

Street Address or Road Name and Number: N1788 HWY R

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): UMLAND, RICHARD L	Lic. #: 89	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 43.2587 °N -88.6259 °W
Address: RICKS WELL & PUMP SERVICE W2721 HWY 33 MAYVILLE WI 53050		Well Plan Approval #	Method Code: GPS008
		Approval Date (mm-dd-yyyy)	SW SE or Govt Lot #: Section: 8 Township: 9 N Range: 16 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

Hicap Permanent Well #	Common Well #	Specific Capacity: 1.7

3. Well serves 1 # of APARTMENT

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	67
6	67	321

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		P		P-HARDPAN	Surface	43
G		X		G-GRAY X-SAND & CLAY	43	67
		L		L-LIMESTONE/DOLOMITE	67	303
		N		N-SANDSTONE	303	321

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK PE 18.97 LBS/FT A53 GR B WHEATLAND STEEL	Surface	69
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

58 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

29 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	67	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RU	89	07-31-2020
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KS	368	07-31-2020

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		64	Building Drain - Sanitary		32
Sewer - Collector - Storm		69	Sewer - Building Sanitary		43

Comment:

Created On: 09-16-2020 Updated On: 10-22-2020 Review Status: APPROVED