

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZB148		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner FONDELL, BOB						Phone # (920)988-1923		1. Well Location				Fire # (if avail.)					
Mailing Address PO BOX 181						Town of HUSTISFORD						N3837					
City CLYMAN						State WI		Zip Code 53016				Street Address or Road Name and Number					
N3837 HWY E						Subdivision Name				Lot #		Block #					
County Dodge		Co. Permit #		Notification # 8261286201		Completed 12-21-2020		Latitude / Longitude in Decimal Degree (DD)				Method Code					
Well Constructor (Business Name) UMLAND, RICHARD L						Lic. # 89		Facility ID # (Public Wells)				43.3328 °N -88.6269 °W		GPS008			
Address RICKS WELL & PUMP SERVICE W2721 HWY 33 MAYVILLE WI 53050						Well Plan Approval #		NE SW		Section 17		Township 10 N		Range 16 E			
						Approval Date (mm-dd-yyyy)		or Govt Lot #		17		10 N		16 E			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3		2. Well Type New Well									
Reason for replaced or reconstructed well ?						of previous unique well # constructed in											
3. Well serves 1 # of HOME						Hicap Well ? No		Reason for replaced or reconstructed well ?									
Private, potable						Hicap Property ? No		Construction Type Drilled									
Heat Exchange ___ # of drillholes						Hicap Potable ? No		Reason for replaced or reconstructed well ?									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8.75		Surface		80		Yes Rotary - Mud Circulation		No		P		P-HARDPAN		Surface		22	
6		80		202		No Rotary - Air		Yes		P C		P-HARDPAN C-CLAYEY		22		80	
						No Rotary - Air & Foam		No		L		L-LIMESTONE/DOLOMITE		80		202	
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		43 ft. below ground surface				16 in. above grade			
6		BLACK P.E. 18.97LBS/FT A-53 G-B WHEATLAND				Surface		81		10. Pump Test				Developed ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 90 ft. below surface				Disinfected ? Yes			
										Pumping at 15 GP M for 1 Hrs.				Capped ? Yes			
										Pumping Method ? Airlift							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?				No	
Method												Filled & Sealed Well(s) as needed?				No	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed	
SODIUM BENTONITE SLURRY				Surface		80				RU				89		01-03-2021	
										Drill Rig Operator				Lic or Reg #		Date Signed	
										KS				368		01-03-2021	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		141	Sewer - Building Sanitary		51
Building Drain - Sanitary		43	Ditch or Culvert		59
			Septic or Holding, or POWTS Tank		90

Comment:

Created On: 02-02-2021

Updated On: 05-07-2021

Review Status: APPROVED